

SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No.

Dated:

It is certified that an inspection team headed by Shri. Anshu Gupta

(Name of Officers with designation) from Assistant Engineer PHED

inspected the Shiv Mahesh Public School, Nevalhia, Munshiganj, Amethi

(Name & Address of the school) on (date of inspection) and on the basis of

Water Test Report (Attached) bearing no. TC-134162600000068F dated 5/2/2026

of NABL (PHED Lab) certified that

the Shiv Mahesh Public School (Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains the

hygienic sanitation condition in the school building & the campus as per norms prescribed by the

Central/ State/ U.T. Govt.

This certificate is valid till 05/02/2026 to 04/02/2027

Signature with Seal:

Name

Designation

Name & Address of the Office / Department

Nigam (Rural)

Amethi

U.P. Jal

Nigam (Rural) Amethi

U.P. Jal

Nigam (Rural) Amethi

U.P. Jal

Nigam (Rural) Amethi

U.P. Jal

Nigam (Rural) Amethi

U.P. Jal

Nigam (Rural) Amethi

U.P. Jal

Nigam (Rural) Amethi

U.P. Jal

Nigam (Rural) Amethi

U.P. Jal

Nigam (Rural) Amethi

U.P. Jal

Nigam (Rural) Amethi

U.P. Jal

Nigam (Rural) Amethi

U.P. Jal

Nigam (Rural) Amethi

U.P. Jal

Nigam (Rural) Amethi



Shri. Anshu Gupta

Assistant Engineer

U.P. Jal

Nigam (Rural) Amethi

U.P. Jal

Nigam (Rural) Amethi

U.P. Jal

Nigam (Rural) Amethi

U.P. Jal

Nigam (Rural) Amethi

U.P. Jal

Nigam (Rural) Amethi

U.P. Jal

Nigam (Rural) Amethi

U.P. Jal

Nigam (Rural) Amethi

U.P. Jal

Nigam (Rural) Amethi

U.P. Jal

Nigam (Rural) Amethi

U.P. Jal

Nigam (Rural) Amethi

U.P. Jal

Nigam (Rural) Amethi

U.P. Jal

Nigam (Rural) Amethi

U.P. Jal

Nigam (Rural) Amethi

U.P. Jal

To
Shiv Mahesh Public School
Nevalhia, Munshiganj, Katramaharaw
(Name & Address of the Institution) Amethi U.P.
Pin - 227412

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies





कार्यालय अधिशासी अभियन्ता खण्ड कार्यालय उ०प्र० जल निगम(ग्रामीण), अमेठी

फोन-9473942559

पत्रांक

दिनांक

सेवा में,

The Principal
Shiv Mahesh Public School,
Nevadhia, Munshiganj, Amethi.

विषय:-पेयजल प्रमाण पत्र निर्गत कराये जाने के सम्बन्ध में।

महोदय,

उपरोक्त विषयक आपके कार्यालय के पत्रांक SMPS/MIS/2026/02 दिनांक 02-02-2026 के संदर्भ में Shiv Mahesh Public School, Nevadhia, Munshiganj, Amethi. के लिये पेयजल से सम्बन्धित प्रमाण पत्र निर्गत करने का अनुरोध किया गया है।

उक्त के सम्बन्ध में विद्यालय द्वारा उपलब्ध कराये गये Submersible Pump के जल नमूने की 14 पैरामीटर की जांच जनपद स्तरीय प्रयोगशाला उ०प्र० जल निगम (ग्रामीण) अमेठी में की गयी, जिसमें पानी की गुणवत्ता संतोषजनक पायी गयी है।

संगलनक:- उपरोक्तानुसार।

भवदीय

(अनिल कुमार राव)
अधिशासी अभियन्ता

पृ०सं०

दिनांक

प्रतिलिपि:-

1. सम्बन्धित सहायक अभियन्ता/जूनियर इंजीनियर (प्रयोगशाला) अमेठी।
2. खण्ड लेखाकार/मुख्य लिपिक/संगणक।

अधिशासी अभियन्ता



Test Report



DISTRICT LEVEL WATER ANALYSIS LABORATORY, UTTAR PRADESH JAL NIGAM(Rural), AMETHI

Certificate No.:TC-13416

Rept No	Test Report/Exec Eng. Con. Divi /Chemical Test/ 390/2025-26		
ULR NO	TC-134162600000068F	Issue Date	5/2/2026
Customer Details		Page No 01	
Office Name and Address		Shiv Mahesh Public School, Nevadhia, Munshiganj, Amethi.	
Ref Letter No & Date		SMPS/MIS/2026/02, 02/2/2026	
District	Amethi	Block	Bhetua
Gram Panchayat	Nevadhia	Village	Nevadhia
Habitation	Nevadhia	Location	Nevadhia
Water Source	Submersible Pump	Sample Code	A/04/02/2408
Quantity of Sample	1.0 Litter	Date of Sample Collection	4/2/2026
Receiving Date	4/2/2026	Sample Collector	Umesh Kumar Pandey
Sample Depositor	Umesh Kumar Pandey	Sampling Method Used.	IS:17614:P-1:2021
Analysis Start Date	5/2/2026	Analysis Completion Date	5/2/2026

Environmental Condition	
Temperature	25±3 oC
Humidity	50±15%

S. No.	Parameter	Units	Observed Value	Specified Values as per		Ref. Method of Analysis
				Acceptable limit	Permissible Limit	
1	2	3	4	5	6	7
1	Turbidity	(NTU)	0.71	1.00	5.00	IS 3025 (Part 10) : 2023
2	pH Value		7.49	6.5-8.5	6.5-8.5	IS 3025 (Part 11) : 2022 (Electrometric Method)
3	TDS	(mg/L)	416	500.00	2000	IS 3025 (Part 16) : 2023
4	Chloride	(mg/L)	17.99	250.00	1000	IS 3025 (Part 32) : 2019
5	Iron (as Fe)	(mg/L)	0.08	0.30	1	APHA 24th Edition-3500-Fe Method B(Phenanthroline) 2023)
6	Sulphate (as SO4)	(mg/L)	24.3	200.00	400	APHA 24th Edition - 4500-SO4 Method E (Turbidity Method),2023
7	Nitrate (as NO3)	(mg/L)	2.49	45.00	45	APHA 24th Edition-4500-NO3 Method D(UV-Screening Method): 2023
8	Total Alkalinity(as CaCO3)	(mg/L)	328	200.00	600	IS 3025 (Part 23) : 2023
9	Total Hardness (as CaCO3)	(mg/L)	224	200.00	600	IS 3025 (Part 21) : 2019
10	Calcium	(mg/L)	40.8	75.00	200	IS 3025 (Part 40) : 2023
11	Magnesium	(mg/L)	29.646	30.00	100	IS 3025 (Part 46) : 2023
12	Taste	Qualitative	Agreeable	-	-	IS 3025 (Part 08) : 2023
13	Odour	Qualitative	Agreeable	-	-	IS 3025 (Part 05) : 2018
14	Colour	Hazen	5	5	15	APHA 24th Edition-2120 Colour Method B(Platinum Cobalts Visual

- Note:
- 1) This certificate refers only to the particular samples (s) submitted for testing.
 - 2) This certificate shall not be reproduced, except in full, unless written permission for the publication of an approved abstract has been obtained from Head Of Laboratory.
 - 3) The test results reported in this certificate are valid at the time of and under the started conditions of measurements.
 - 4) Sample will be stored up to 7 days (in case of non perishable items only) from the date of issue of tests reports unless otherwise specified.

Neha Maurya
Prepared By
Neha Maurya
(Deputy Technical Manager)

Chandra Prakash Sharma
Authorised signatory
Chandra Prakash Sharma (Technical Manager)
Technical Manager
District Level Water Analysis Laboratory
Amethi, UPJN

Laboratory Contact Details :- Name - Chandra Prakash Sharma
Mo.No.- 9628474106


End of the report

**PROFORMA REGARDING SAFE DRINKING WATER AND SANITARY CONDITION
CERTIFICATE.**

No. Memo/07/26Date : 18.04.2026

It is certified that an inspection team headed by DR. PITAMBER -
KANAUJIYA S.M.O. DISTT. HOSPITAL GAURIGANJ (Name of Officers
 with designation) from DISTT. HOSPITAL GAURIGANJ (Name of
 Department/Office) inspected the SHIV MAHESH PUBLIC SCHOOL
NEVADHIA, MUNSHIGANJ, KATARAMAHARANI AMETHI (Name & Address of
 the School) on 16.04.2026 and found that the SHIV MAHESH PUBLIC
SCHOOL (Name of school) has safe
 drinking water facilities for the students and members of staff of the institution and is maintaining
 the hygienic sanitation condition in the school building & the campus as per the norms
 prescribed by the Central/State/U.T Govt.

The above valid for a period of 2 years.

Signature with Seal : 

Name : _____

Designation : Dr. Pitamber Kanaujiya
Consultant
 District Combined Hospital
 Gauriganj, Amethi
 Reg.No.-57288

To

ManagerShiv Mahesh Public School,Nevadhia Munshiganj Kataramaharani

(Name & Address of the Institution)

Munshiganj Amethi U.P.